

**2026 EML Renewables and Storage RFP**

RFP Documents – Excel Workbook Updates

<b>RFP Document</b>	<b>Tab</b>	<b>Question</b>	<b>Cell</b>	<b>Redline</b>
<b>Appendix D-1 Preliminary Due Diligence Questionnaire – Solar</b>	Sec. 3 – Project Development	3.5.11	C47	ASCE 7: Risk Category III
<b>Bidder Registration Form</b>	Bidder Registration Form	N/A	A25	Will the proposal include <del>options alternative(s)</del> that <del>make modifies</del> the <del>point of</del> financial settlement <del>point</del> (PPA/ESA only) and/or the <del>wind speed risk category</del> (solar proposals only) <del>at the generator bus instead of the EML Load Node?</del> If <del>so yes</del> , please specify how many and which modification(s) are included for this submission <del>such options will be included?.</del>
<b>Proposal Submission Template</b>	PST	N/A	A61	Added Question <u>Confirm the proposal meets Wind Speed Risk Category III requirements. Note: A Category II design is only permitted as part of an alternative, solar bid.</u>